# Facility Defense Against Aerosol Attack

**Dan Cousins** 

(781) 981-1904

cousins@II.mit.edu

3 April 2002



MS-15434

This work was sponsored under Air Force contract F19628-00-C-0002. The views expressed are those of the Author and do not reflect official policy or position of the United States Government.

Report Documentation Page				
Report Date 03APR2002	Report Type N/A	Dates Covered (from to) 03APR2002 - 04APR2002		
Title and Subtitle Facility Defense Against Aerosol Attack		Contract Number F19628-00-C-0002		
		Grant Number		
		Program Element Number		
Author(s) Cousins, Dan		Project Number		
		Task Number		
		Work Unit Number		
Performing Organization Name(s) and Address(es) MIT Lincoln Laboratory		<b>Performing Organization Report Number</b>		
Sponsoring/Monitoring Agency Name(s) and Address(es) Air Force ESC/XPK (Richard Axtell) Hanscom AFB, MA 01731		Sponsor/Monitor's Acronym(s)		
		Sponsor/Monitor's Report Number(s)		
Distribution/Availability Statement Approved for public release, distribution unlimited				
Supplementary Notes  Workshop paper from the New England Bioterrorism Preparedness Workshop held 3-4 april 2002 at MIT Lincoln Laboratory, Lexington, MA, The original document contains color images.				
Abstract				
Subject Terms				
Report Classification unclassified		Classification of this page unclassified		
Classification of Abstract unclassified		Limitation of Abstract SAR		
Number of Pages				



### **Outline**

- Facilities and attack scenarios
- Sensing an attack
- Facility protection techniques




### Types of facilities

- Simple structures
  - Residences, barracks
- Buildings with ventilation system
  - Multiroom office building
  - Large open space (arena, terminal, ...)
- Subway
- Outdoor sites
  - Stadium
  - Public gathering
  - Military operations



## **Simplified Ventilating System**





## **Types of Attacks**

- External attacks
  - Nearby cloud release
  - Burst release into air intake
- Internal attacks
  - Burst release into air return
  - Burst release into a large open space
  - Low level continuous release
- Small amounts of agent are substantial threats


1 gram bioagent uniformly dispersed into 10<sup>8</sup> liter building (100m x 100m x 10m);


Corresponds to lethal exposure (100 ppl x 10 liter/min x 10 min; 10<sup>10</sup> particles /gram)

## **Modeling an Attack**

#### Burst release in an interior room

- Bioagent 15 grams over 5 sec
- Room-Hall coupling 10%





- •Lumped parameter models are well established instantaneous and uniform concentration within each room
- •Initial particle dispersal and deposition are more complicated to model.



### **Emergency Management Measures**

#### Information

- Observing suspicious activity
- Knowing who to treat
  - Primarily, but not exclusively, bio agents
  - Records of access (badge swipes, tickets,...)
  - Voluntary response to public announcement
  - Physical examination
- Preserving forensic evidence

#### Plan of action

- HVAC emergency management decision tree
  - > Suspicious event near air intake -> shut down intake
  - Suspicious event inside building -> full fresh air
- Communication channels
- Evacuation plan
  - Orderly movement to controlled safe area, avoid cross contamination



### **Outline**


- Facilities and attack scenarios
- Sensing an attack
- Facility protection techniques

## Rationale for Sensing

- Issue alarm
  - initiate facility response
  - high Prob<sub>detection</sub>; low Prob<sub>false alarm</sub>; wide range of agents
- Identification of agent
  - initiate medical treatment
- Mapping of contamination zone
- Assessing decontamination ("all-clear")




### State-of-the-Art Bio / Chem Sensors






## **Sensor Architectures for Building Defense**





### **Atmospheric Aerosol Content**




After R. Jaenicke in Aerosol-Cloud-Climate Interactions, P. Hobbs editor (1993).



## **False Trigger Rate**


•Sensor will trigger less frequently when operated at higher threshold.





### **Indoor Standoff Aerosol Detection**

- •Any point sensor is limited by aerosol transport in large open space.
- •Need to detect the release promptly at a specific point
- •Bio sensor concept:



### Minimum for detecting 1000ppl threat

	Dwell time	Range cell
Elastic	0.1 sec	1 m
UV LIF	10 sec	3 m
Diff SWIR	10 sec	2 m

50m range, eyesafe laser; 100 lux lighting



### **Outline**

- Facilities and attack scenarios
- Sensing an attack
- Facility protection techniques



## **Facility Protection Measures**

- Physical security
  - Protect fresh air intakes (location, access, surveillance)
  - Personal screening (may be difficult in civil defense)
- Ventilation system protection
  - Passive air filtration
    - Upgrade filters (best ASHRAE filters > 95%)
    - Overhauling the system (HEPA / carbon)
  - Positive pressure to overcome infiltration
  - Sensor triggered airflow control

### **Passive Air Filtration**

- In-line passive filtration is well established
  - HEPA filters remove >99.97% suspended particles > 0.3 um.
  - Activated carbon filters adsorb most chemical vapors
- Substantial cost to overhaul existing ventilation system
  - Purchase and replacement of filters
  - Increased blower motors for higher pressure drop
  - Reinforced ductwork
  - Very little infiltration is allowable (gasket seals, overpressure)
  - Increased energy costs
- Research topics
  - Low pressure drop filter structures
  - In-line sterilization (UV, radiation, thermal,...)



## **Facility Defense Effectiveness**

Estimated exposure reduction to external bio attack

"Unprotected" building	1
Upgraded standard filters     (or in-room HEPA)	10-100
• In-line HEPA filters	100-1000
In-line HEPA filters     with overpressure     and triggered airflow control	> 1000



## **Summary**

- Most buildings with ventilation systems are vulnerable to aerosol attack via a number of scenarios.
- Without deployed sensors, an attack may go undetected resulting in higher exposure and lack of treatment to exposed occupants.
- There are some simple measures that can be used to increase situational awareness and provide limited protection.
- A substantial degree of protection can be achieved at substantial cost with sensor triggered airflow control and HEPA/carbon filters. In this case, sensors may be operated at higher thresholds.